

消防處
牌照及審批總區
通風系統課
香港新界葵涌興盛路86號消防處
葵涌辦公大樓3字樓



FIRE SERVICES DEPARTMENT
LICENSING & CERTIFICATION COMMAND
Ventilation Division

3/F, Fire Services Department Kwai Chung Office Building,
No. 86 Hing Shing Road, Kwai Chung, Hong Kong

本處檔號 Our Ref.: FP (LC) 317/21
來函檔號 Your Ref.: HTL022/2020
圖文傳真 Fax: 2367 3206
電話 Tel. No.: 3961 5299

19 October 2020



Hip Tung Cables Co., Ltd.
Room 1312D Witty Commercial Building,
1A-1L Tung Choi Street,
Kowloon,
Hong Kong

(Attn: Mr. Eddie YUNG)

Dear Sir,

**“Nexans” Fire Resistant Cables –
Alsecure Plus Series (NX100, NX300, NX400 and NX600)**

I refer to your letter dated 15.9.2020 enclosing a set of catalogues, authorization letter and certificates with respect to the captioned products for the assessment of this Department.

According to FSD Circular Letter no. 1/2007, any fire service installation / equipment (except portable equipment, i.e. fire extinguisher, fire blanket, etc.) which is certified and properly listed by one of our recognized Product Certification Bodies (PCBs) is deemed to be accepted by this Department subject to (i) no change of the listing condition; and (ii) such equipment and the installation being in conformity with all relevant local requirements.

The application for the captioned products acceptance by this Department is not necessary subject to their valid LPCB listing in compliance with current version of BS 6387:2013 Cat. CWZ, BS 7846:2015, BS 8434-2:2013+A2:2009 and EN 50200:2015 as listed in the LPCB Redbook and their correct cable markings.

Yours faithfully,

(Stanley CHOW)
for Director of Fire Services

cc: Internal:
Engr(FSI)2
CTO(Vent) – Fax : 2382 2495

SC/WLC
FileCode: Nexans Alsecure Plus NX series FR cables_20201019