

# CERTIFICATE of Conformity



Registration No.: AK 60168185 0001

Report No.: TR22CHYH 001

Holder: NEXANS TURKIYE ENDUSTRI VE TIC. AS.  
MECIDIYEKÖY MAH. OGUZ SOKAK NO:4  
4 RONESANS BIZ PLAZA KAT: A/1  
MECIDIYEKÖY  
34387 İSTANBUL  
Türkiye

Product: Cable  
(Power Cables)

Identification: Type Designation, Number of Cores and Cross-sectional area:  
CU/XLPE/PVC 2...4X1,5...400mm<sup>2</sup>  
CU/XLPE/PVC 5X1,5...95mm<sup>2</sup>  
CU/XLPE/PVC 7...48X1,5...2,5mm<sup>2</sup>  
CU/XLPE/PVC 1X1,5...1000mm<sup>2</sup>  
Trademark: NEXANS  
Rated voltage: U<sub>o</sub>/U 0,6/1kV

Tested acc. to: IEC 60502-1:2021

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 10.03.2023



Certification Body

Paulus Hou

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg